



Noise Monitoring Result

Day Time (0700 - 1900hrs on normal weekdays)

Location: M4a - Caseway Bay Community Centre

Date	Time	Weather	Measurement Noise Level			Baseline Noise Level	Construction Noise Level
			Leq	L10	L90	Leq	Leq
Unit: dB(A), (30min)							
23 Mar 2010	10:41	Sunny	65.8	67.2	63.3	68.6	65.8 Measured \leq Baseline Noise Level

Location: M5b - City Garden

Date	Time	Weather	Measurement Noise Level			Baseline Level	Construction Noise Level
			Leq	L10	L90	Leq	Leq
Unit: dB(A), (30-min)							
23 Mar 2010	09:53	Sunny	66.2	67.6	64.1	-	66.2



Noise Monitoring Result



Restricted Time (1900 - 2300 hrs on normal weekdays and 0700-2300 on holiday)

Location: M4a - Caseway Bay Community Centre

Date	Time	Weather	Measurement Noise Level			Average Noise Level	Baseline Noise Level	Construction Noise Level
			Leq	L10	L90	Leq	Leq	Leq
Unit: dB(A), (5-min)								
23 Mar 2010	22:42	Fine	61.7	63.2	59.2	61.6	66.7	61.6 Measured \leq Baseline Noise Level
	22:47		61.5	63.4	58.5			
	22:52		61.7	63.5	58.5			

Location: M5b - City Garden

Date	Time	Weather	Measurement Noise Level			Average Noise Level	Baseline Level	Construction Noise Level
			Leq	L10	L90	Leq	Leq	Leq
Unit: dB(A), (5-min)								
23 Mar 2010	22:17	Fine	63.5	65.0	61.2	63.9	-	63.9
	22:23		64.2	65.7	61.5			
	22:27		64.1	66.0	61.0			





Graphic Presentation of Noise Monitoring Result

Restricted Time (1900 - 2300 hrs on normal weekdays and 0700-2300 on holiday)

