



Ref. No.	Date	Time	Location	Construction Noise Level, dB(A)	Parameter	Action Level	Limit Level dB(A)	Follow-up action
X_19N014	6-Jan-20	13:10	M4b - Victoria Centre	77	Leq(30min)	when one documented complaint was received.	75	Possible reason: Non-CWB project material handling work immediately next to the monitoring station and traffic nearby were observed as the major noise contribution during monitoring. Action taken / to be taken: A repeat measurement was conducted to confirm result and reviewed the trend of previous noise monitoring and Contractor's working procedure. Remarks / Other Obs: No construction works was conducted under HY/2009/19 around the monitoring location while non-CWB project material handling work immediately next to the monitoring station was observed as the major noise contribution during monitoring. As such, the exceedance was considered as non-Project related.
X_19N015	6-Jan-20	13:10	M4b - Victoria Centre	77	Leq(30min)	when one documented complaint was received.	75	Possible reason: Non-CWB project material handling work immediately next to the monitoring station and traffic nearby were observed as the major noise contribution during monitoring. Action taken / to be taken: A repeat measurement was conducted to confirm result and reviewed the trend of previous noise monitoring and Contractor's working procedure. Remarks / Other Obs: No construction works was conducted under HY/2011/08 around the monitoring location while non-CWB project material handling work immediately next to the monitoring station was observed as the major noise contribution during monitoring. As such, the exceedance was considered as non-Project related.



Ref no.	Date	Location	Parameter (Unit)	Construction Noise Level, dB(A)	Action Level	Limit Level	Follow-up action
RTN_2020.01_1	3 January 2020	RTN4 - Causeway Bay Community Centre	Leq (30min)	Refer to Appendix 5.4	When one documented complaint was received.	75	After checking with the Contractors, no construction activities was conducted under Contractor HY/2009/19 and HY/2011/08 around the monitoring station on 3 January 2020. As such, the exceedance was considered as non-Project related.
RTN_2020.01_2	9, 22 and 23 January 2020	RTN 3 - Yu Lee Mo Fan Memorial School	Leq (30min)	Refer to Appendix 5.4	When one documented complaint was received.	75	After checking with the Contractors, no construction activities was conducted under Contractor HY/2009/19 around the monitoring station on 9, 22 and 23 January 2020, while non-CWB project material handling work immediately next to the monitoring station was observed as the major noise contribution during monitoring. As such, the exceedance was considered as non-Project related.